

A decorative graphic on the left side of the slide, consisting of four overlapping circular frames. The top frame shows solar panels, the middle frame shows a large industrial facility with cooling towers, the bottom-left frame shows a helicopter near a power line, and the bottom-right frame shows a worker on a power line.

LV Embedded Generation Hosting Capacity

2014/11/12

Powering your world



- Background
- Grid Code and NRS documents
- HBM modification
- Scenarios tested
- Results
- Conclusions
- Recommendations

- Grid connection code for renewable power plants (RPPs) connected to the electricity transmission system (TS) or the distribution system (DS) in South Africa (RPP grid code)
 - Category A: $0 < S < 1$ MVA (LV connected only)
 - A1: $0 < S \leq 13.8$ kVA
 - A2: $13.8 \text{ kVA} < S < 100$ kVA
 - A3: $100 \text{ kVA} \leq S < 1$ MVA
- NOTE: $S > 4.6$ kVA must be balanced three-phase
- Category B: $1 \text{ MVA} < S < 20$ MVA
 - Category C: $S \geq 20$ MVA

- Connection rules, technical requirements etc. fairly well defined for RPPs in categories B and C
 - Planning and quotation phases
 - Grid Code compliance simulations and testing
 - Contracts:
 - Connection Agreement
 - Power Purchase Agreement
 - Operational Agreement
 - Eskom connection requirements
- Category A gaps partially covered by NRS 097-2-1 (Ed1)
 - Edition 2 intends to close some of the gaps (and in line with RPP GC)


- Connected to LV
 - Rule-of-Thumb < 1 MVA (NRS097-2-1 and RPP GC)
- Planning / design phase for each application?
 - Combined impact on network / other installations?
- Control of each installation?
 - SCADA?
 - Forecasting?
- Safety of installation
 - Customer installation safety
 - Utility personnel

- NRS 097-2 series of documents:
- NRS 097-2-1: Utility interface (Ed2 in preparation)
- NRS 097-2-2: Type testing (in preparation)
- NRS 097-2-3: Simplified utility connection criteria for LV connected generators
 - Flow-chart with simplified acceptance criteria
 - LV connection length related to voltage rise
 - Meet NRS 097-2-1 technical requirements
- Research to inform the simplified acceptance criteria as well as more detailed studies for more “complex” applications


- Prof Trevor Gaunt, Dr Ron Herman and Emmanuel Namanya
- Evaluate the hosting capacity of LV feeders based on load and generation patterns
- Focus
 - SSEG (connected to LV)
 - Voltage rise – steady state variations
 - PV with inverter
 - High-income customers (LSM7-8)
- Modified Herman-Beta algorithm to include varying generation along with varying loads

- Characteristic load profiles
 - LSM 7-8
 - Variation of load and generation
 - Single-phase vs. three-phase
 - Solar Water Heating
(Excluded in first phase)

Moreletta Park Load Profile



Moreletta Park Summer Load Profile with solar PV



- Characteristic Topology
 - Linear or branched feeder
 - Loss of diversity on branches
 - Range of number of customers
 - 6 – 40 customers per feeder
 - Customers per node
 - Clustered from 1 customer per kiosk up to 6 customers per kiosk
 - PV Connections
 - No constraint on position
 - Can be three-phase
 - Limited to 60A per node


- Characteristic Embedded Generation
 - Maximum size of PV
 - Current limit of 25% of size of connection, e.g. 15A for 60A breaker capacity
 - Research to be expanded to 50% of connection size
 - Daily variation of PV output
 - As per rating of PV installation
 - Orientation and shadowing
 - Actual installation
 - Assume perfect installation with no shadowing (i.e. maximum)
 - Generators modelled as negative loads
 - Similar to loads in HBM – use current to characterize the generator

- Constraints
 - PV installations only
 - Source voltage at nominal
 - Passive feeders: assume maximum of 10% voltage drop for maximum load
 - With PV generation -> maximum of 10% voltage rise at any node
 - No reverse power flow allowed to MV network
 - 10% risk (90% confidence) levels selected

NOTES:

1. Source voltage usually above nominal
2. European standards typically allow 3% voltage rise on a feeder due to EG


- CASE 1 (Base case)
 - Load: High LSM, single-phase load profiles (seasonal high and low)
 - Number of customers: 18 (3 per node)
 - PV: Single-phase, 1 kW, randomly distributed on nodes & phases
 - Increments of 1kW with any number of units assigned to any node using Monte Carlo with H-B (DG)
 - Results to be used as guide to further variations



- As in Case 1 but with lumped 3.5kW single-phase PV
- As in Case 1 but with lumped 10kW three-phase units
- As in Case 1 but with branch of 2 nodes at node 2
 - Lumping near source
- As in Case 1 but with an increased source voltage


- Design for maximum voltage drop using winter load
- The parameters of the load model are:
 - Winter peak load used to size the conductor: $a=1.09$; $b=2.22$; $c=61.48$ A; $admd=4.657$ kW; $V_s=230$ V; resultant voltage drop = 10%.
 - Load for maximum difference between PV profile and load profile, at 13:15 in summer: $a=0.628$; $b=1.233$; $c=22.602$ A; $admd=1.76$ kW; $V_s=230$ V
 - The parameters of the 1 kW PV module are:
 - $a=255$; $b=255$, $c=8.696$ A
 - (Note: The large a and b parameters represent a virtually fixed load or source with negligible dispersion and with mean current of half the value of c)

- Design feeder for maximum voltage drop using winter load




Case 1: Max Feeder Voltage Scatter Plot

- Maximum difference between load and generation found at 13:15 (summer load)
- 1kW PV




Case 1: Max Feeder Voltage Scatter Plot (2)

- Simulating extremes... create envelope




Case 2: Max Feeder Voltage Scatter Plot

- 3.5kW single-phase generators




Case 3: Max Feeder Voltage Scatter Plot

- 10kW three-phase generators




Case 4: Branched Feeder at Node 2




Case 4: Max Feeder Voltage Scatter Plot

- 1kW single-phase generators



Case 5: Max Feeder Voltage Scatter Plot

- 1kW single-phase generators
- Increased source voltage



- The modified Herman Beta method is a powerful tool to analyse the impact of generators on LV voltage regulation
- Approximately 30-35% penetration of design load demand can be tolerated:
 - Allowing for an elevated source voltage
 - Risk level of 10%
- Compares favourably with the 25% of customer demand (breaker size) limit contained in NRS097-2-3
- Three-phase EG allows for a larger penetration percentage

- Aspects not yet researched:
 - Thermal loading of LV conductors/cables
 - Effect of reverse power flow into MV network
 - Further LV feeder configurations
 - Control modes for PVEG (support for network voltage)
 - Correlation of solar water heating and PVEG
 - Impact of LV network unbalance on hosting capacity (link to proposed penetration limits)
 - Quality of Supply impacts, e.g. voltage variations (flicker) and harmonics

A decorative graphic on the left side of the slide, consisting of two overlapping circles. The top circle shows a large industrial facility, likely a power plant, with a tall cooling tower and various structures. The bottom circle shows two people, a man and a woman, sitting at a table and engaged in a discussion. The background of the slide is white with a blue curved shape on the left side.

Thank you